

# RANCHO SANTIAGO COMMUNITY COLLEGE DISTRICT

## ADDENDUM NO. 1

Quote # QU016.004

Centennial Education Center(CEC) – Security Office Interior Improvements.

January 19, 2016

Owner:  
Rancho Santiago Community College District  
2323 North Broadway Room 112  
Santa Ana, California 92706

RECEIPT OF THIS ADDENDUM MUST BE ACKNOWLEDGED ON  
QUOTE FORM WHEN SUBMITTED

ADDENDUM NO. 1

Project Manager		1/15/16	Date
Director		1/19/16	Date
Assistant Vice Chancellor			

The following changes, additions, deletions or corrections shall become a part of the Contract Documents for the project named above and all other conditions shall remain the same. The bidders shall be responsible for transmitting this information to all affected subcontractors and suppliers prior to the closing of bids. Prospective Bidders shall acknowledge receipt of this Addendum in the space provided on the Quote Form. Failure to do so may subject Bidder to disqualification.

**Item No. AD-1-1: Door Hardware.**

1. Provide and install door closer and existing entry door. LCN 4111 - Heavy Duty Parallel Arm Adjustable Closer

**Item No. AD-1-2: Electrical Lighting.**

1. Provide and install (2) new 2'x4' light fixtures in the Hallway outside of the Locker Room. The new light fixtures are to be similar to the existing fixtures.
2. Relocate (1) existing light fixture in the Office as required for installation of new wall.

**Item No. AD-1-2: Interior Painting.**

1. Delete P1 Prep and Painting requirement for the Work Station Room, Locker Room and Hallway to Office. The Office is still to receive P1.

**This is the end of Addendum No. 1**