

RANCHO SANTIAGO COMMUNITY COLLEGE DISTRICT

ADDENDUM NO. 1

Request for Solicitation

Dunlap Hall 4th Floor Restroom Alteration, Santa Ana College

June 28, 2016

Owner:
Rancho Santiago Community College District
2323 North Broadway Room 112
Santa Ana, California 92706

RECEIPT OF THIS ADDENDUM MUST BE ACKNOWLEDGED ON BID FORM WHEN SUBMITTED

ADDENDUM NO. 1

The following changes, additions, deletions or corrections shall become a part of the Contract Documents for the project named above and all other conditions shall remain the same. The Contractors shall be responsible for transmitting this information to all affected subcontractors and suppliers prior to the submittal of their Quotes. The Contractor shall acknowledge receipt of this Addendum in the space provided on the Quote Form. Failure to do so may subject Contractors to disqualification.

Item No. AD-1-1:

The following information is being provided in response to questions asked by prospective bidders:

1. **Question:** The boxes under the lavatory does not appear to be an insta-hot. They appear to be the controls for the censored faucet. Is this correct?

Answer: Yes they are the controls for the sensors.

2. **Question:** Do these fixtures have concealed carriers in the walls?

Answer: Yes, the fixtures do have concealed carriers.

3. Question: Is there adequate amount of water & waste piping in the walls to operate fixtures when switch lavatories are 1.F.U & Urinals are 3.F.U?

Answer: The existing piping to each of the fixtures is $\frac{3}{4}$ ".

Item No. AD-1-2:

The due date and time for receipt of quotes is changed to Thursday June 30 at 10:00 am.

End of Addendum #1