



Building the future through quality education

2323 North Broadway • Santa Ana, CA 92706 -1640 • (714) 480-7300 • www.rsccd.edu

Santa Ana College • Santiago Canyon College

REQUEST FOR PROPOSALS #1415-94

Santiago Canyon College at Energy Management System Upgrades

Addendum # 3

March 30, 2015

**The following changes, additions, deletions or corrections shall become part of the
Request for Proposal for Energy Management System Upgrades**

Please note the following clarification to existing equipment configuration located at Building A and Building B. The buildings do not have existing air cooled chillers. Instead the equipment is split system air cooled condensers.

Revisions:

Bldg. A Existing Configuration: (23) VAVs with HHW reheat, (1) AHU SF and (1) RF (with SF and RF VFD Control). (1) Boiler and (1) ***Split System Air Cooled Condenser Unit*** and multiple EFs

Note: The condenser and boiler were replaced with new high efficiency units in summer 2009.

Bldg. B Existing Configuration: (23) VAVs with HHW reheat, (1) AHU SF and (1) RF (with VFD Control). (1) Boiler and (1) ***Split Systems Air Cooled Condenser Unit*** and multiple EF units

Note: The chiller and boiler were replaced with new high efficiency units in summer 2009.

End of Addendum # 3